

ANNEXURE - A

Existing E.H.V.T. S/S with transformer capacity and M.D. reached so far.

Sr. No.	Name of the Sub-station	Tahsil	Transformer Ratio and Capacity	Max. load in MVA	Date and Month
1.	220/110/11 KV Kop-II S/S	Karveer	1X20 KVA 220/110/11 KV 3X100 MVA 220/110/11 KV	137.64 MVA	March 1982.
2.	110/33/11 KV Kop-I	Karveer	1X25 MVA 110/11 KV 1X12.5 MVA 110/33 KV 2X25 MVA 110/33 KV	59.1 MVA	Jan. 1981
3.	110/33/11 KV Ichalkaranji S/s	Hatkana-gale.	1X25 MVA 110/33 KV 1X20 MVA 110/33 KV 2X25 MVA 110/11 KV	58.27 MVA	Sept. 1981
4.	110/33/11 KV Jaysingpur S/s	Shirol	2X10 MVA 110/33 KV 1X10 MVA 110/11 KV	28.4 MVA	June 1981
5.	110/33/11 KV Radhanagari S/s	Radhana-gari.	2X10 MVA 110/33 KV 1X3 MVA 33X11 KV	22.5 MVA	May 1982
6.	110/33/11 KV Kale S/s.	Panhala	1X10 MVA 110/33 KV 1X10 MVA 110/11 KV	15.0 MVA	Feb. 1982

(Source : Maharashtra State Electricity Board Kolhapur Circle,
Details of electrification in Kolhapur District as
on 31-10-1983.)